



LOAD SHEDDING SCHEDULE FOR THE DRY SEASON 2019

No	FEEDERS	Max. Load per Feeder	Time	Mon	Tues	Wed	Thurs	Fri	Sat	Sun	7pm-1am Hydro Operations
1	Point-4 (LEC Bushrod Substation, Point-4, New Kru Town, Caldwell, Duala and up to St, Paul Bridge)	2.5MW	7am-7pm	ON/Full	OFF/TOTALY	ON/Full	OFF/TOTALY	ON/Full	ON/Full	ON/Full	ON/Full
2	Port Feeder(LEC Bushrod Substation, Bong Mines bridge, Logan Town, Jamaica Rd., NPA, LPRC, Clara town, Vai town, Slip-way, and the entire Somalia drive up to Chicken Soup Factory)	4.5MW	7am-7pm	OFF/TOTALY	ON/Full	OFF/TOTALY	ON/Full	OFF/TOTALY	ON/Full	ON/Full	ON/Full
3	Mamba Point(Waterside Substation, WestPoint, Johansson, US embassy, EU office, New Port street, , Finance Ministry, New Port St & UN Drive)	1.8MW	7am-7pm	ON/Full	OFF/TOTALY	ON/Full	OFF/TOTALY	ON/Full	ON/Full	ON/Full	ON/Full
4	Water & City(Central Monrovia)	3.5MW	7am-7pm	ON/Full	ON/Full	ON/Full	ON/Full	OFF/TOTALY	OFF/TOTALY	ON/Full	ON/Full
5	Capitol/Congo Town(Capitol Substation-LNP Head quarter on Capitol Hill, Jallah Town, Saye Town, Sinkor, Airfield, Matadi,	8.0MW	7am-7pm	ON/Part	ON/Part	ON/PART	ON/Full	ON/Part	ON/Full	ON/Full	ON/Full

	Old Road and Up to Nigeria House)										
6	Capitol/Kru Town(Capitol Substation-LNP Head quarter on Capitol Hill, Bassa Community, Buzzi quarter, UN Drive and up to New Port Street)	1.15MW	7am-7pm	ON/Full	ON/Full	ON/Full	ON/Full	ON/Full	ON/Full	ON/Full	ON/Full
7	Express To Water Treatment Plant(LEC Bushrod Substation – coffee)	1.0MW	7am-7pm	ON/Full	ON/Full	ON/Full	OFF/TOTALY	OFF/TOTALY	ON/Full	ON/Full	ON/Full
8	Paynesville/Red Light(Paynesville substation, Red light,72nd, Jacob town, St. Francsi, St. Tolbert Estate and up to chicken soup factory)	5.0MW	7am-7pm	ON/Part	ON/Part	ON/Part	ON/Full	ON/Full	ON/Full	ON/Full	ON/Full
9	Paynesville /Congo Town(Paynesville substation, LBS, Entire ELWA, Congo Town and up to Nigeria House)	2.7MW	7am-7pm	ON/Full	OFF/TOTALY	ON/Full	OFF/TOTALY	OFF/TOTALY	ON/Full	ON/Full	ON/Full
	Total Max. Load on feeders	30.15MW									
	ESTIMATED LOAD REDUCTION EXERCISE			15.09MW	12.68MW	17.07MW	17.09MW	17.08MW	19.57MW	22.68MW	MAX 35MW DURING PEAK

LEC 22KV NETWORK LOAD SHEDDING SCHEDULE FOR DRY SEASON 2019

COMMENTS: On part indicates that circuit or Feeder will be isolated at a prescribed location for load reduction purpose. IE

1. Port Feeder-----Open gang switch @ Total gas station on Somalia drive
2. Capitol/Congo Town-----Open gang switch #3 @ Saye Town #1 main road
3. Paynesville Red/Light-----Open cutouts @ LBDI Bank Red Light community main road

	ON
	OFF
	ON PART – NOT ALL COMMUNITIES ARE ON